

**APPENDIX “A”– INFRACTIONS is hereby added to read as follows:**

**ENFORCEMENT**

The Fire Chief of the District is designated as the Chief Fire Official of the District. The Fire Chief and his/her designated Fire Marshal shall have all the powers of peace officers in enforcing the California Fire Code; pursuant to Section 830.37 of the California Penal Code. The Fire Marshal may issue orders, notices, and citations and make arrests for violations within the South Placer Fire District; pursuant to Section 13870, 13871, 13872, 13872.5 and 13873 of the California Health and Safety Code.

**109.4 Violation penalties.** Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under the provisions of this code, shall be guilty of an infraction. Each infraction will be punishable by an administrative fine, in accordance with Government Code Section 53069. (b) Every violation determined to be an infraction is punishable by (1) a fine of one hundred dollars (\$100) for a first violation; (2) a fine of two hundred dollars (\$200) for a second violation of the same ordinance within one year; (3) a fine of five hundred dollars (\$500) for each additional violation of the same ordinance within one year.

**2016 California Fire Code**

Section	Offense
107.7	Occupant count - Overcrowding
307.1.1	Prohibited open burning
307.5	Attendance - open burning
308.1.2	Throwing or placing sources of ignition
308.3.1	Open-flame decorative devices
308.1.8	Fire protection – flaming food and beverage preparation
309.4	Fire extinguishers – industrial trucks and equipment
310.2	Prohibited areas – smoking
310.4	Removal of signs prohibited
310.5	Compliance with “No Smoking” signs
503.4	Obstruction of fire apparatus access roads
503.5.1	Secured gates and barricades
505.1	Address identification
507.5.4	Obstruction – fire protection equipment
604.4	Maintenance – emergency power systems
605.3	Obstructing electrical service equipment
605.4	Multi-plug adapters
605.5	Extension cords
605.6	Unapproved conditions – outlets and junction boxes
605.10.4	Prohibited areas – electric space heaters
606.7	Emergency signs – mechanical refrigeration
609.3.3	Cleaning of grease removal devices, hoods, and ducts

703.1	Maintenance of fire resistant construction
703.2	Fire doors – obstructing or impairing operation
703.3	Decorative materials attached to fire-rated ceilings
901.4.5	Imitation fire protection device
901.7	Failure to notify fire department – system out of service
905.7	Obstructing or obscuring fire appliance cabinets
906.6	Obstructing or obscuring fire extinguishers
906.7	Mounting of fire extinguishers
907.8	Inspection, testing and maintaining fire alarm system
1004.3	Posting of occupant load sign
1011.7.4	Storage under exterior exit stairways
1028.5	Obstructing or obscuring exits
1031.4	Maintenance of exit signs
2304.4.1	Dispensing flammable liquid into unapproved container
2304.4.3	Location of portable container while dispensing
2311.3.2	No smoking – repair garage
2403.2.6	No smoking – flammable finishes
2403.2.7	No welding signs – flammable finishes
2403.4.3	Combustible waste and residue disposal
2404.4.1	Fire extinguishers – spraying areas
2404.7.8.5	Disposal of used filters
2405.3.4	Dip-tank covers
2405.4.2	Fire extinguishers – dipping operations
2406.4.2	Fire extinguisher – powder coating operations
2406.5	Dust accumulation – powder coating operations
3103.12.6	Posting of exit signs – tents
3103.12.6.1	Exit sign illumination
3304.1	No smoking – construction and demolition areas
3304.2.2	Combustible waste disposal
3317.3	Fire extinguisher – roofing operations
3504.2.6	Fire extinguisher – hot work areas
5303.4	Marking of compressed gas containers
5303.5.3	Securing compressed gas containers
5704.2.3.1	Posting no smoking signs - flammable / combustible liquids
5803.1.4.2	Posting no smoking signs – flammable gases
6107.2	No smoking – LPG containers
6107.3	Clearance from combustible material – LPG containers