

South Placer Fire District Underground-LPG Permit Application

6900 Eureka Road, CA 95746

Administration Office Number (916) 791-7059 Fax (916) 791-2199

Office Hours Monday-Friday 8:00am – 5:00pm

(Closed for Lunch from 12:00pm-1:00pm)

Plan review by:

Permit Application Fee: \$250.00

Regular plan review will take a minimum of 4 weeks

Expedite Fee Charge \$336.24 per submittal plus regular fee: ☐ Yes ☐ No (Expediting your plans will take approximately 10-business days)

Date: _____

Placer County Plan Check Number: _____

Project Name: _____

Project Address: _____

Owner Contact Information

Name: _____ Day Number: _____

Address: _____ Fax: _____

City: _____ Zip: _____ E-Mail: _____

Installation of underground LPG tanks shall meet California Fire Code Article 82, NFPA 54, NFPA 58 and the following Fire District requirements:

1. Contact the Fire District before installation to have the Fire Marshal present during tank installation. Fire Marshal must also be present for a final inspection of the installation before the tank is back-filled.
2. Submit complete Underground Tank Installation and Corrosion Control Examination Form to the Fire District. (Forms are available through the Western Propane Gas Association at 559-897-8812).
3. Conduct s Voltage Test once each calendar year and submit a Corrosion Control Examination Form to the Fire District. (Forms are available through the Western Propane Gas Association at 559-897-8812).
4. A permanent placard shall be placed on the outside of the main electrical panel to the building. The placard shall be at least 3" X 3" and read "Underground Propane Tank".
5. A remote shut-off valve shall be located at the structure and clearly marked with a 3" X 3" placard that reads "Propane Shut-Off".
6. Precaution shall be taken to prevent damage to the tank coating during handling. Any damage to the tank's coating shall be repaired prior to back-filling.
7. All nonmetallic underground piping must have a tracer wire (14 AWG minimum) or tape for its full length.
8. No portion of the tank shall be located less than 10' from buildings, public ways, easements, or lines of adjoining properties.
9. When necessary to prevent flotation or high water table, the tank shall be securely anchored.
10. Disclosure to a new homeowner of the underground tank is required. Discloser shall include requirement of the annual voltage test to monitor corrosion (cathodic protection) ensuring tank integrity and safety.

For questions concerning tank installation, contact Rob Scott at 559-897-8812. For inspections, contact the Fire District at 916-791-7059.

South Placer Fire District Copy

Effective January 1, 2019 Check #: _____ Check Amount: _____

— — —



Date _____



CORROSION CONTROL EXAMINATION FORM

Company Name: _____ Customer: _____
Company Address: _____ Tank Location: _____
City: _____ Date of Inspection: _____
State: _____
Zip Code: _____
Age of Line (Years): _____ Age of Container (Years): _____
Line Size: _____ Container Size (Gallons): _____

Container Manufacturer: _____ Number of Anodes: _____
Container Serial Number: _____ Type of Anodes: _____
Condition of Right of way: _____
Anodes Voltage Test Results: _____

Voltage test results	
Test	Voltage
Test 1:	
Test 2:	
Test 3:	
Test 4:	

Tank Test Location

The above annual container voltage test was performed by _____

The above container has: Passed all tests _____ Failed all tests _____

If the container failed the above listed tests the following corrective action must be taken
before it can be placed back in service:

Service Technician

Date

